

# VOC Content Test Certificate

Tuesday 14<sup>th</sup> November 2023

Supplier: Jacobsen Creative Surfaces Ltd (41D Morrin Road, St Johns, Auckland 1072, New Zealand).

Product name: J-System 12 Pressure Sensitive Carpet Tile

Date Tested: October 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

<b>Specification</b> <b>New Zealand Green Building Council</b> <b>Green Star Design &amp; As Built V1.1-13.1.1B</b> <b>Green Star Interiors V1.1-12.1.1B</b>	<b>J-System 12 Pressure Sensitive</b> <b>Carpet Tile</b>
<b>General Purpose Adhesives and Sealants Limit:</b> <b>50 grams per litre</b>	<b>40 grams per litre as VOC content per</b> <b>material</b>
<i>We hereby certify J-System 12 Pressure Sensitive Carpet Tile is below the VOC Content limits of chosen category specified by Green Star Interiors, Green Star Design &amp; As Built, New Zealand Green Building Council.</i>	

Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant

Dr. Tuan Duong  
PhD, BE (Chemical Engineer)  
Senior Consultant

Travis Hale  
BSc (Biotechnology)  
Senior Consultant