

VOC Content Test Certificate

Friday 3rd November 2023

Supplier: Jacobsen Creative Surfaces Ltd (41D Morrin Road, St Johns, Auckland 1072, New Zealand).

Product name: J-System 13 High Moisture Acrylic Adhesive

Date Tested: October 2023 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-05 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

Specification New Zealand Green Building Council Green Star Design & As Built V1.1-13.1.1B Green Star Interiors V1.1-12.1.1B	J-System 13 High Moisture Acrylic Adhesive
General purpose adhesives and sealants Limit: 50 grams per litre	37 grams per litre as VOC content per material

We hereby certify J-System 13 High Moisture Acrylic Adhesive is below the VOC Content limits of chosen category specified by Green Star Interiors, Green Star Design & As Built, New Zealand Green Building Council.

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Dr. Tuan Duong
PhD, BE (Chemical Engineer)
Senior Consultant

Travis Hale
BSc (Biotechnology)
Senior Consultant